



Flextech Industries Inc. meets NSF/ANSI 372 lead free requirements

Flextech Industries flexible sample products have been tested (by a laboratory in compliance with all applicable requirements of ISO/IEC 17025) in accordance to NSF 372 guidelines to comply with lead free requirements.

Our applicable submittal drawings will contain the following paragraph:
All wetted surfaces of this product contain less than .25% lead content as required by NSF 372 standard specifications.

Copy of the test report can be obtained by contacting Flextech Industries.